302 B - 11

Commercial Complax, Ranjeet Nagar, New Delhi- 110008 Phone 011 - 25700168, 9099554242 , 9899554242 email : dwtl@watersupermart.com • www.delhiwatertestlab.com







Test Certificate No.: DWGTL/23-24/088 EC  Party's Name: Maharaja Agarsain Public School  Ashok Vihar,  New Delhi-110052					Issue Date:  Ref. No.:  Protocol Used:	27/07/2023 Nil IS:10500-2012
Date of Sample Receipt: 25/07/2023 Types of w Sample Collected by: Party				iter: Dinking water Lab cook.		DWGTL/23-24/088 EC 25/07/23 to 27/07/23
Physical analysis	S.N	Parameters		Test Results	Requirements	Test method Used
	1.	Color		<1	5	IS:3025 Pt-4-2002
	2.	Odor		Agreeable	Agreeable	IS:3025 Pt-5-2002
	3.	Taste		Agreeable	Agreeable	IS:3025 Pt-8-2006
	4.	Turbidity, NTU		0.4	1	IS:3025 Pt-10-2006
	5.	рН		7.84	6.5-8.5	IS:3025 Pt-11-2002
Chemical analysis	6.	Total Dissolved Solid, mg/l		129	500	IS:3025 Pt-16-2002
	7.	Total Iron as Fe, mg/I		0.05	0.3	IS:3025-Pt53-2009
	8.	Total Hardness as CaCO <sub>3</sub> , mg/I		36	300	IS:3025 Pt-21-2009
	9.	Chlorides as Cl, mg/l		24.8	250	IS:3025 Pt-32-2002
	10.	Residual Free chlorine, mg/l		0.04	0.2	IS:3025 Pt-26-2003
	11	Sulphate as SO4, mg/l		11.6	200	IS:3025pt-24-2009
	12	Fluorides as F-, mg/l		0.12	1.0	IS:3025-Pt60-2003

G. Singh Checked by Sr. Chemist

Authorized signatory

## WE UNDERTAKE TESTING OF: WATER \* AIR \* EFFLUENTS \* MATERIALS

The above result are related only to the sample. Endorsement of products is neither inferred nor implied, this report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media with out our special written permission. Samples will be destroyed after 15 days from the date of reporting unless otherwise specified.

Total liability of laboratory is limited to the invoiced amount.

Approved by the Municipal Coporation of Delhi (Health Deptt)